

ADDENDUM 3



Engineering Study of Fall Protection Systems Forsyth County Facilities

**Qualifications Will Be Received Until
12:00 Noon, Friday, December 8, 2017**

**By The City of W-S/Forsyth Co. Purchasing Department
In Room 324 City Hall Building
101 North Main Street
Winston-Salem, North Carolina**

November 7, 2017

Please acknowledge receipt of this Addendum and include with your proposal.

Company

Authorized Signature

Date

QUESTIONS / RESPONSES

Q - Is a North Carolina contractor's license required for work on this project?

A - The RFQ is referring to an State of North Carolina Engineer's License, only engineering recommendation/consultation and fall protection inspection work are included, no construction at this time.

Q - Is there a limit to how many buildings will be available for the inspection and evaluation after award? For example, can all 47 buildings be inspected during one mobilization to site(s) or will only certain buildings be available during a given time frame? If so, how many buildings can be inspected during a given mobilization?

A - Yes, upon award, all buildings are available for immediate inspection during normal business hours.

Q - We received your RFQ for the above referenced project. We may be interested in submitting for this project; however, we do have a question regarding the project intent. The description mentions 'inspection' of 47 facilities, 43 of which may or may not have fall protection already installed. Is this 'inspection' to determine locations for installation of new fall protection, or to verify existing systems?

A - The project involves inspection and certification of four (4) facilities with existing systems and inspection and determination if a system is required on remaining facilities per OSHA Walking-Working Surfaces and Personal Fall Protection Systems Final Rule (29 CFR part 1910, subpart D and I).